

CERTIFICATE of Conformity



Registration No.: AK 50588019 0001

Report No.: CN21MHN7 002

Holder: Guangzhou Sanjing Electric Co., Ltd.
No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Product: PV-Inverter
(Grid-Connected PV Inverter)

Identification: Type Designation: R5-6K-S2-IE, R5-6K-S2-15-IE
Firmware Version: V2.011
Compliant to : -Requirement to Type A Generation Unit.
COMMISSION REGULATION (EU) 2016/631 (RfG).
Remark : Refer to test report CN21MHN7 002
for details.

Tested acc. to: EN 50549-1:2019

The certificate of conformity refers to the above mentioned product. This is to certify that the specimen is in conformity with the assessment requirement mentioned above. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity.

Certification Body

Date 26.05.2023



Tongle Lee

Tongle Lee

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

Guangzhou Sanjing Electric Co.,
Ltd.

Date : 26/05/2023
Our ref. : Lied 02
Your ref.: 168428105

No.9, Lizhishan Road, Science City,
Guangzhou High-tech Zone,
Guangdong
P.R. China

Ref : AK Certificate of Conformity

Type of Equipment : Grid-Connected PV Inverter
Model Designation : See Certificate
Certificate No. : AK 50588019 0001
Report No. : CN21MHN7 002

Dear Ladies and Gentlemen,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Tongle Lee

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询